

## Spill Summary Report for NRC Report #1245091

Report Date: 9/14/2022

Report Time: 4:07 PM EDT

## Region II Hotline Log Entry Information

Data ID: 2540328

Date Of Report: 5/9/2019

NRC #: 1245091

State #:

ERNS #:

Material Type: Haz

Receiver: Paul Kahn

Material / Amount:

DIELECTRIC FLUID NON-PCB (200 GALLON(S));

Location:

Street: 7 RIDGEHILL LANE  
 City: YONKERS  
 County: WESTCHESTER  
 State: NY  
 Latitude: 40.95382476303005  
 Longitude: -73.85540649988165

Source of Pollution:

CONSOLIDATED EDISON COMPANY OF NEW YORK

Water Body:

State Or EPA Responded:

RP/PRP Responded

Initial EPA Action:

Called RP for follow-up information

Status:

2 - Closed

URL:

## Associated Action Reports

DataID: 1248836

Date: 5/9/2019	Time: 08:53:46	
Duty Officer/Responder Name: Paul L. Kahn	NRC Report #: 1245091	Hotline Log DataID: 2540328
<b>Action Information</b>		
<b>Description:</b> This report is a follow-up report to the initial report to the NRC made by Con-Ed on 5/8/2019 (ID2540145). The initial report did not include the volume of PCBs released. This updated report notified the NRC that 200 gallons of PCB di-electric fluid were released from the underwater section of an electrical feeder cable from Yonkers NY to upper Manhattan. Con-Ed is still investigating the location of the release and will call the NRC with an update when that information is available.		
<b>Follup-Up:</b> Contacted PRP		
<b>Person Contacted</b>		
<b>Name:</b> Dennis Rohere <b>Organization:</b> Con-Edison <b>Phone #:</b> 212-580-8383		

## NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

\*\*\*GOVERNMENT USE ONLY\*\*\*GOVERNMENT USE ONLY\*\*\*

Information released to a third party shall comply with any  
 applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 1245091

INCIDENT DESCRIPTION

\*Report taken by NRC at 07:34 on 09-MAY-19

Incident Type: PIPELINE

Incident Cause: UNKNOWN

Affected Area:

Incident occurred on 09-MAY-19 at 07:10 local incident time.

Affected Medium: WATER / HUDSON RIVER

REPORTING PARTY

Name: DENNIS ROHERE

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

Address: 3101 20TH AVENUE

ASTORIA, NY 11105

Email Address: rohrerd@coned.com

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: DENNIS ROHERE

Organization: CONSOLIDATED EDISON COMPANY OF NEW YORK

ASTORIA, NY 11105

PRIMARY Phone: (212)5808383

Type of Organization: PUBLIC UTILITY

INCIDENT LOCATION

7 RIDGEHILL LANE County: WESTCHESTER

City: YONKERS State: NY

---

RELEASED MATERIAL(S)

CHRIS Code: OMN      Official Material Name: OIL, MISC: MINERAL  
Also Known As: DIELECTRIC FLUID NON-PCB  
Qty Released: 200 GALLON(S)      Qty in Water: 0 UNKNOWN AMOUNT

---

---

DESCRIPTION OF INCIDENT

CALLER IS REPORTING A POTENTIAL RELEASE OF DIELECTRIC FLUID NON PCB TO WATER. A POSSIBLE RUPTURE IN THE TRANSMISSION LINE FEEDER IS UNDER THE HUDSON RIVER. INVESTIGATIONS ARE UNDERWAY TO DETERMINE THE LOCATION OF THE POSSIBLE DISCHARGE.

---

---

INCIDENT DETAILS

Pipeline Type: TRANSMISSION  
DOT Regulated: UNKNOWN  
Pipeline Above/Below Ground: BELOW  
Exposed or Under Water: NO  
Pipeline Covered: UNKNOWN

---

---

IMPACT

Fire Involved: NO      Fire Extinguished: UNKNOWN  
INJURIES: NO      Sent to Hospital:      Empl/Crew:      Passenger:  
FATALITIES: NO      Empl/Crew:      Passenger:      Occupant:  
EVACUATIONS: NO      Who Evacuated:      Radius/Area:  
Damages: NO

<u>Closure Type</u>	<u>Description of Closure</u>	<u>Hours Closed</u>	<u>Direction of Closure</u>
Air: NO			
Road: NO			Major Artery: NO
Waterway: NO			
Track: NO			

Passengers Transferred: NO  
Environmental Impact: UNKNOWN  
Media Interest: UNKNOWN      Community Impact due to Material:

---

---

REMEDIAL ACTIONS

INVESTIGATION UNDERWAY  
Release Secured: UNKNOWN  
Release Rate:  
Estimated Release Duration:

---

---

WEATHER

---

ADDITIONAL AGENCIES NOTIFIED

Federal:  
State/Local:  
State/Local On Scene:  
State Agency Number:

---

---

NOTIFICATIONS BY NRC

CENTERS FOR DISEASE CONTROL (GRASP)  
09-MAY-19 07:43 (770)4887100  
DEPT OF HEALTH AND HUMAN SERVICES (SECRETARY'S OPERATION CENTER (SOC))  
09-MAY-19 07:43  
DHS DEFENSE THREAT REDUCTION AGENCY (CHEMICAL AND BIOLOGICAL TECHNOLOGIES DEPARTMENT)  
09-MAY-19 07:43 (703)7673477  
DHS INFRSTR SECURITY COMPLIANCE DIV (REGION 2)  
09-MAY-19 07:43 (202)4655909  
DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)  
09-MAY-19 07:43 (202)3661863  
U.S. EPA II (MAIN OFFICE)  
09-MAY-19 07:55 (732)3214370 KAHN  
NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)  
09-MAY-19 07:43 (202)2829201  
NJ OFC HMLND SECURITY & PREPAREDNESS (COMMAND CENTER)  
09-MAY-19 07:43 (609)9636817  
NJ STATE POLICE (MARINE SERVICES BUREAU)  
09-MAY-19 07:43 (609)9636900  
NOAA RPTS FOR NY (MAIN OFFICE)  
09-MAY-19 07:43 (206)5264911  
NTSB PIPELINE (MAIN OFFICE)  
09-MAY-19 07:43 (202)3146293

NEW YORK CITY DEP (BUREAU OF WATER SUPPLY)  
09-MAY-19 07:43 (845)3347188  
NY STATE DEC SPILL HOTLINE (MAIN OFFICE)  
09-MAY-19 07:43 (518)4577362  
PIPELINE & HAZMAT SAFETY ADMIN (OFFICE OF PIPELINE SAFETY (AUTO))  
09-MAY-19 07:43 (202)3660568  
REPORTING PARTY (RP SUBMITTER)  
09-MAY-19 07:43  
SECTOR NEW YORK (COMMAND CENTER)  
09-MAY-19 07:57 (718)3544356 SCRANTON  
CTDEP OIL & CHEM SPILL RESP DIV (MAIN OFFICE)  
09-MAY-19 07:43 (860)4243338  
USCG DISTRICT 1 (COMMAND CENTER)  
09-MAY-19 07:43 (617)2238555

---

ADDITIONAL INFORMATION

/// IN REFERENCE TO NRC INCIDENT REPORT # 1245032 ///

---

\*\*\* END INCIDENT REPORT # 1245091 \*\*\*  
Report any problems by calling 1-800-424-8802  
PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>